



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

General Coatings Manufacturing Corp.
1220 E. North Ave
Fresno, CA 93725, United States

Plant Location:

Fresno, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 01/06/2021

Material/Product:

Silicone Roof Coating

Contact Temperature:

23 ± 2°C

Models:

Ever-Silic HS
Ultra-Guard 5700



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 9000

Maximum tank surface area/volume ratio (sq in/L): 2.7

Maximum dry film thickness per coat (mils): 30

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at $23 \pm 2^\circ\text{C}$

Mix ratio: Single-Component

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.