



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Mueller Industries, Inc.
150 Schilling Blvd
Suite 100
Collierville, TN 38017, United States

Plant Location:

Fulton, MS, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 01/22/2019

Material/Product:

Pipe and Related Products - Tubing/Hose

Contact Temperature:

82 ± 2°C

Models:

Streamline ≥ 1/2"

Copper tube (Alloy C12200) is Certified to NSF/ANSI 61-2017 for use in drinking water suppliers of pH 6.5 and above. Drinking water supplies that are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.