



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Mueller Industries, Inc.
150 Schilling Blvd
Suite 100
Collierville, TN 38017, United States

Plant Location:

Cedar City, UT, United States

Standards:

NSF/ANSI/CAN 61 - 2020
NSF/ANSI/CAN 372 - 2020

Certificate:

Issued Date: 01/22/2019

Material/Product:

Pipe and related Products - Pipe

Contact Temperature:

82 ± 2°C

Models:

Streamline >= 1/2"

Copper tube (Alloy C12200) is Certified to NSF/ANSI 61-2017 for use in drinking water suppliers of pH 6.5 and above. Drinking water supplies that are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.