



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Max Air Technology, Inc.  
114 Resource Drive,  
Wentzville, MO 63385, United States

**Plant Location:**

Ninjin, China

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 10/11/2024

**Material/Product:**

Butterfly Valves

**Contact Temperature:**

82 ± 2°C

**Models:**

Ductile Iron Butterfly Valves (250/251) (1)  
Iron and Aluminum Bronze Body Butterfly Valves (050/051) (1)  
SS Body Butterfly Valves (650/651) (1)

Footnote (1): The Certified materials could be one of the followings:

(1) For Valve Discs (½" to 48"):

Aluminum Bronze, Stainless Steel, Nylon 11 coated Iron, PTFE coated SS.

(1) For Valve Seats (½" to 48"):

EPDM, Food Grade EPDM (one black, one white), NBR (one black, one white), Natural Rubber, PTFE lined EPDM, Silicone.