



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Max Air Technology, Inc.
114 Resource Drive,
Wentzville, MO 63385, United States

Plant Location:

Ninjin, China

Standards:

NSF/ANSI/CAN 61 - 2020
NSF/ANSI/CAN 372 - 2020

Certificate:

Issued Date: 07/09/2020

Material/Product:

Butterfly Valves

Contact Temperature:

82 ± 2°C

Models:

Iron Body Butterfly Valves (050/051) (1)
SS Body Butterfly Valves (650/651) (1)

Footnote (1): The Certified materials could be one of the followings:

(1) For Valve Discs (½" to 24"):

Aluminum Bronze, Stainless Steel, Nylon 11 coated Iron, PTFE coated SS.

(1) For Valve Seats (½" to 24"):

EPDM, Food Grade EPDM (one black, one white), NBR (one black, one white), Natural Rubber, PTFE lined EPDM, Silicone.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.