



## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

Mueller Industries, Inc.  
150 Schilling Blvd  
Suite 100  
Collierville, TN 38017, United States

**Plant Location:**

London, ON, Canada

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI/CAN 372 - 2022

**Certificate:**

Issued Date: 01/22/2019

**Material/Product:**

Pipe and Related Products - Tubing/Hose

**Contact Temperature:**

82 ± 2°C

**Models:**

Streamline Copper Water Tube  $\geq 1/2"$   
Streamline PlumbShield  $\geq 1/2"$

Copper tube (Alloy C12200) is Certified to NSF/ANSI 61-2017 for use in drinking water suppliers of pH 6.5 and above. Drinking water supplies that are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.