



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

CLA-VAL
1701 Placentia Avenue
Costa Mesa, CA 92627, United States

Plant Location:

Costa Mesa, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 02/22/2019

Material/Product:

Direct Acting Regulating Valve

Contact Temperature:

23 ± 2°C

Models:

CRD-L 1/2" - 2.5"

A minimum flow rate of 30L/day is required for this product.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.