



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Specton Construction Products Ltd.
12 Wallace Street,
Acton, Ontario L7J2V6, Canada

Plant Location:

2160 Wommelgem, Belgium

Standards:

NSF/ANSI/CAN 61 - 2020

Certificate:

Issued Date: 04/30/2019

Material/Product:

Polyurethane Injection resin

Contact Temperature:

23 ± 2°C

Models:

SPECTON FLEX F1000
SPECTON FLEX LV

The Surface area of a product touches water should not exceed more than 1% coverage of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 80000

Maximum tank surface area/volume ratio (sq in/L): 1.32

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at 23 ± 2 °C

Final cure time: 24 hours at 23 ± 2 °C

Mix ratio: 10: 1: 0.5 (resin/accelerator/water)

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.