



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Nukote Coating Systems International
4730 Consulate Plaza Dr
Suite 100
Houston, Texas 77032, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

Nukote MetalPrime II & Nukote XT Plus - Polyurethane Barrer Material

Contact Temperature:

23 ± 2°C

Models:

Nukote MetalPrime II
Nukote XT Plus



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 500000

Maximum tank surface area/volume ratio (sq in/L): 0.72

Maximum dry film thickness per coat (mils): 120

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 24 hours at $23 \pm 2^\circ\text{C}$

Final cure time: 24 hours at $23 \pm 2^\circ\text{C}$

Mix ratio: 1:1 by volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS