



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

AmTech Coatings, LLC
75-4 Main St. Suite 300
Plymouth, NH 03264, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 05/13/2019

Material/Product:

Spray Polyurea

Contact Temperature:

23 ± 2°C

Models:

DuraChem 500 SERIES



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 800

Maximum tank surface area/volume ratio (sq in/L): 6.3

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48hrs @ 23°C

Shortest cure time between coats or layers: 60min @ 23°C

Final cure time: 48hrs

Mix ratio: 1:1 by Volume

Colors: Natural

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.