



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Mueller Industries, Inc.  
150 Schilling Blvd  
Suite 100  
Collierville, TN 38017, United States

**Plant Location:**

Howell Metal company, New Market, VA

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI/CAN 372 - 2022

**Certificate:**

Issued Date: 05/28/2019

**Material/Product:**

Tubing/Hose

**Contact Temperature:**

83 ± 2°C

**Models:**

Copper Water Tube 1/4" - 2 1/2"  
Copper Water Tubing 1/4" - 2 1/2"  
Hard Copper Water Tube 1/4" - 2 1/2"  
Hard Copper Water Tubing 1/4" - 2 1/2"  
Soft Copper Water Tube 1/4" - 2 1/2"  
Soft Copper Water Tubing 1/4" - 2 1/2"

Copper tube (Alloy C12200) is Certified to NSF/ANSI 61 for use in drinking water supplies of pH 6.5 and above. Drinking water supplies that are less than pH 6.5 may require corrosion control to limit the leaching of copper into the drinking water.