



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

NCFI Polyurethanes  
1515 Carter St  
Mt. Airy, NC 27030, United States

**Plant Location:**

Mt. Airy, NC, United States

**Standards:**

NSF/ANSI/CAN 61 - 2024  
NSF/ANSI 372 - 2024

**Certificate:**

Issued Date: 04/14/2025

**Material/Product:**

Geotechnical Foam System

**Contact Temperature:**

23 ± 2°C

**Models:**

NCFI 24-003



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 100

Maximum tank surface area/volume ratio (sq in/L): 13.3

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hr @ 23Â°C

Final cure time: 24 hr

Mix ratio: 1:1 by Volume

Colors: Gray

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Product water contact should not exceed 5% of total wetted surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.