



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Sanipur US LLC
2201 Barren Hill Road
Conshohocken, PA 19428, United States

Plant Location:

Conshohocken, PA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 06/10/2019

Material/Product:

Monochloramine Water Disinfection Generator System

Contact Temperature:

60 ± 2°C

Models:

Sanikill (all models)
Sanikill-LITE
Sanikill-TEC*

NSF/ANSI 61 addresses health effects only and does not address the disinfection efficacy of the product.

*Model treats water at 23°C



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.