

# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## **Certified Product Listing**

#### For:

Drinking Water System Components - Health Effects

#### Company:

Wolverine Coatings Corporation 5969 Highway 221 Roebuck, SC 29376, United States

#### **Plant Location:**

Roebuck, SC, United States

#### **Standards:**

NSF/ANSI/CAN 61 - 2022 NSF/ANSI 372 - 2022 NSF/ANSI/CAN 600 - 2021\*

#### **Certificate:**

Issued Date: 04/29/2024

#### **Material/Product:**

**Epoxy** coating

#### **Contact Temperature:**

23 ± 2°C

#### Models:

LiquaTile 1172-012 LiquaTile 1172-020 LiquaTile 1172-030 LiquaTile 1172-060 LiquaTile 1172-125

\*NSF/ANSI/CAN 61 certified products meet the health effects criteria in NSF/ANSI/CAN 600.







10450 Stancliff Rd. Suite 210 Houston, Texas 77099

### **Material Characteristics:**

Minimum pipe diameter (inches): 16

Maximum pipe surface area/volume ratio (sq in/L): 108.4 sq cm/L

Minimum tank size (gallons): 50

Maximum tank surface area/volume ratio (sq in/L): 108.4 sq cm/L

Maximum dry film thickness per coat (mils): 9\*\*-125

Number of coats: Maximum two coats

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to

manufacturer instructions for details

Final cure time: 16 hours

Mix ratio: 2:1 Resin to Hardener

Colors: Grey (GY1D), Blue (BU1A) and White (WH1A)

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

#### Additional comments:

This product was tested without a primer or an additional topcoat. It is recommended that any primer or topcoat used should be certified to NSF/ANSI/CAN 61 by an ANSI accredited certifier.

NSF/ANSI/CAN 61-certified products meet the health effects criteria in NSF/ANSI/CAN 600.

\*\* Two 9mil coats must be applied for a minimum total thickness of 18mil



