



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

NCFI Polyurethanes
1515 Carter St
Mt. Airy, NC 27030, United States

Plant Location:

Mt. Airy, NC, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 12/16/2024

Material/Product:

Polyurethane Foam

Contact Temperature:

23 ± 2°C

Models:

NCFI 24-044
NCFI 24-044 FAST



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 1

Maximum pipe surface area/volume ratio (sq in/L): 244

Minimum tank size (gallons): 10

Maximum tank surface area/volume ratio (sq in/L): 32

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23Â°C

Shortest cure time between coats or layers: 50-80 sec (NCFI 24-044) / 20-25 sec (NCFI 24-044 FAST)

Final cure time: 48 hours

Mix ratio: 1:1 vol

Colors: Yellow

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

Product water contact should not exceed 5% of total wetted surface area.