



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

NCFI Polyurethanes  
1515 Carter St  
Mt. Airy, NC 27030, United States

**Plant Location:**

Mt. Airy, NC, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 11/22/2024

**Material/Product:**

Isocyanate Prepolymer

**Contact Temperature:**

23 ± 2°C

**Models:**

NCFI 24-120 without catalyst



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 72

Maximum pipe surface area/volume ratio (sq in/L): 3.4

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23Â°C

Shortest cure time between coats or layers: 5 min

Final cure time: 48 hours

Mix ratio: 10:1 pbw

Colors: Yellow

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.