



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

GCP Applied Technologies, Inc.
62 Whittemore Avenue
Cambridge, Massachusetts 02140, United States

Plant Location:

Heist-op-den Berg, Belgium

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 10/23/2020

Material/Product:

Barrier Material

Contact Temperature:

23 ± 2°C

Models:

Silcor 900MP

The Silcor 900MP is certified for use with Silcor Primer EPF.



Material Characteristics:

Minimum tank size (gallons): 500

Maximum tank surface area/volume ratio (sq in/L): 7.5

Maximum dry film thickness per coat (mils): 80 mils

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Yes

(1) Type of coat: Primer

(2) Number of additional coats: 1

Total cure time and temperature: 15 min/60-70°F

Shortest cure time between coats or layers: 2 seconds

Final cure time: 15 minutes

Mix ratio: 1:1 vol

Colors: Gray

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.