



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Isotec International, Inc.
201 Longview St
Canton, Georgia 30114, United States

Plant Location:

Canton, Georgia, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 11/10/2020

Material/Product:

Coating

Contact Temperature:

23 ± 2°C

Models:

IsoCoat Tank Lining PW



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 18

Maximum pipe surface area/volume ratio (sq in/L): 13.6

Minimum tank size (gallons): 100

Maximum tank surface area/volume ratio (sq in/L): 13.3

Maximum dry film thickness per coat (mils): 80 mils

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Yes

(1) Type of coat: Primer

(2) Number of additional coats:

Total cure time and temperature: 24 hours @ 23Â°C

Shortest cure time between coats or layers: 20 seconds

Final cure time: 48 hours

Mix ratio: 1:1 vol

Colors: Gray

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes