



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

HMI
4466 Custer St
Manitowoc, Wisconsin 54220, United States

Plant Location:

Manitowoc, Wisconsin, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 07/12/2024

Material/Product:

Barrier Material

Contact Temperature:

23 ± 2°C

Models:

RR 401 FAST

This product is not intended to contact drinking water inside of a tank or pipe. Instead, it is designed for raising concrete or other geotechnical applications outdoors and may come into contact with less than 1% of groundwater/runoff



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 6

Maximum pipe surface area/volume ratio (sq in/L): 40.7

Minimum tank size (gallons): 500

Maximum tank surface area/volume ratio (sq in/L): 7.5

Maximum dry film thickness per coat (mils): 1/2

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23 Â°C

Shortest cure time between coats or layers: 30 minutes

Final cure time: 48 hours

Mix ratio: 1:1 vol

Colors: Gray

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.