



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Tremco Inc.
23150 Commerce Park
Beachwood, OH 44122, United States

Plant Location:

Toronto, ON, Canada

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 08/20/2024

Material/Product:

TremPro Chem-X Pro

Contact Temperature:

60 ± 2°C

Models:

Tremco TremPro Chem-X Pro (Black)
Tremco TremPro Chem-X Pro (Grey)
Tremco TremPro Chem-X Pro (White)



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum tank size (gallons): 5000

Maximum tank surface area/volume ratio (sq in/L): 3.3

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Mix ratio: A single component.

Colors: White, Gray, Black

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

The surface area of Trempro Chem-X touches water should not exceed more than 10% coverage of the total surface area.

ALS