



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

NCFI Polyurethanes
1515 Carter St
Mt. Airy, NC 27030, United States

Plant Location:

Missouri City, Texas, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 07/31/2024

Material/Product:

Rigid Foam System

Contact Temperature:

23 ± 2°C

Models:

NCFI 24-010



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum tank size (gallons): 5

Maximum tank surface area/volume ratio (sq in/L): 40.4

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23Â°C

Final cure time: 24 hours

Mix ratio: 1:1 by Volume

Colors: Natural

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Product water contact should not exceed 5% of total wetted surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.