



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Kirkhill Rubber Company, A Hexpol Company
2500E Thompson St.
Long Beach, CA 90505, United States

Plant Location:

Long Beach, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 09/03/2024

Material/Product:

NBR

Contact Temperature:

82 ± 2°C

Models:

60 NBR
70 NBR
75 NBR

Certification for a maximum wetted surface area to volume ratio of 1.6 cm²/L.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.