



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

HMI  
4466 Custer St  
Manitowoc, Wisconsin 54220, United States

**Plant Location:**

Manitowoc, Wisconsin, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 03/26/2021

**Material/Product:**

One-Component Soil-Stabilizer

**Contact Temperature:**

23 ± 2°C

**Models:**

RR 600

ALS



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 60

Maximum pipe surface area/volume ratio (sq in/L): 4.1

Minimum tank size (gallons): 8,000

Maximum tank surface area/volume ratio (sq in/L): 2.9

Maximum dry film thickness per coat (mils): 0.5 mil

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23Â°C

Shortest cure time between coats or layers: Dependent on moisture content of soil

Final cure time: 120 hours

Colors: Amber

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.