



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

HMI
4466 Custer St
Manitowoc, Wisconsin 54220, United States

Plant Location:

Manitowoc, Wisconsin, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 03/26/2021

Material/Product:

One-Component Soil-Stabilizer

Contact Temperature:

23 ± 2°C

Models:

RR 600



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 60

Maximum pipe surface area/volume ratio (sq in/L): 4.1

Minimum tank size (gallons): 8,000

Maximum tank surface area/volume ratio (sq in/L): 2.9

Maximum dry film thickness per coat (mils): 0.5 mil

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/23Â°C

Shortest cure time between coats or layers: Dependent on moisture content of soil

Final cure time: 120 hours

Colors: Amber

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.