



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Zurn Wilkins
1747 Commerce Way
Paso Robles, CA 93446, United States

Plant Location:

China #2, China

Standards:

NSF/ANSI/CAN 372 - 2020

Certificate:

Issued Date: 04/12/2021

Material/Product:

Backflow Preventer (950XL3 & 975XL3)

Contact Temperature:

NA

Models:

950XL3 (Size 1-1/4" - 2")

975XL3 (Size 1-1/4" - 2")

975XL3 (Size 1-1/4" - 2")

Options: (Any combination of options may be used)

None - Standard ball valves and test cocks

L - Less shut-off valves

FT - Test cocks with integral male 45° (1-1/4"-2")

S - Includes model SXL Strainer on inlet (1-1/4"-2")

U - With Union Ball Valves (1-1/4"-2")

SE - Includes street elbows (1-1/4"-2")

950XL3 (Size 1-1/4" - 2")

Options: (Any combination of options may be used)

None - Standard ball valves and test cocks

L - Less shut-off valves

FT - Test cocks with integral male 45° (1-1/4"-2")

S - Includes model SXL Strainer on inlet (1-1/4"-2")

U - With Union Ball Valves (1-1/4"-2")



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.