



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Sigma DG Corporation  
5019 NW 127 Street  
Vancouver, Washington 98685, United States

**Plant Location:**

Gisborne, New Zealand

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 11/05/2021

**Material/Product:**

Fiberglass

**Contact Temperature:**

23 ± 2°C

**Models:**

Sigma Fiberglass Form Ties

The product is certified for the maximum wetted surface area to volume ratio of 15 cm<sup>2</sup>/L



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.