



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 12/07/2021

Material/Product:

PSE 95A - Polyeuro Barrier Material

Contact Temperature:

23 ± 2°C

Models:

PSE 95A

ALS



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 200000

Maximum tank surface area/volume ratio (sq in/L): 0.97

Maximum dry film thickness per coat (mils): 70

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 48 hrs

Mix ratio: 1:1 Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS