



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 08/26/2024

Material/Product:

Polyliner & Polyprime - Polyurethane Barrier Material

Contact Temperature:

23 ± 2°C

Models:

Polyliner 21-F
Polyliner 3042F
Polyprime 21
Polyprime 3042



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 30,000

Maximum tank surface area/volume ratio (sq in/L): 1.8

Maximum dry film thickness per coat (mils): 500 (12.7 mm)

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs at $23 \pm 2^\circ\text{C}$

Mix ratio: 2:1:6 by Volume (A:B:C)**

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Flushing or preparation instruction prior to use:
Please refer to manufacturer's instruction.

** Mix Ratio:

2:1:6 by volume(A:B:C) (For Polyliner 21-F & Polyliner 3042-F)

Mix Ratio:

2:1 by volume (A: B) (For Polyprime 21 & Polyprime 3042)