



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Bedford, TX, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 07/18/2024

**Material/Product:**

Polyeuro PLC 80 - Spray applied Polyurethane Coating

**Contact Temperature:**

23 ± 2°C

**Models:**

Polyeuro PLC 80



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 4

Maximum pipe surface area/volume ratio (sq in/L): 61

Minimum tank size (gallons): 1,000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Maximum dry film thickness per coat (mils): 120

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours at  $23 \pm 2^\circ\text{C}$

Mix ratio: 1:1 Volume

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.