



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

SippTech LLC
565 W Douglas
Suite 204
Wichita, KS 67213, United States

Plant Location:

St. Louis, MO, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 09/29/2022

Material/Product:

Polyurethane Pipe Coating.

Contact Temperature:

23 ± 2°C

Models:

TSTRATA ML-440



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum pipe diameter (inches): 8

Maximum pipe surface area/volume ratio (sq in/L): 30.5

Maximum dry film thickness per coat (mils): 3000

Number of coats: 5

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 48 hrs @ 25Å°C

Final cure time: 48 hrs

Mix ratio: 1:1 by Volume

Colors: Blue

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.