



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Freedom Chemical Corporation
19685 Descartes
Foothill Ranch, CA 92610, United States

Plant Location:

Foothill Ranch, CA, US

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 09/04/2024

Material/Product:

Spray-Applied Polyurea Waterproofing Membrane

Contact Temperature:

23 ± 2°C

Models:

Freedom Tuff 2210PW



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 100

Maximum tank surface area/volume ratio (sq in/L): 13.3

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 24 hours

Mix ratio: 1:1 by Volume

Colors: Aqua Blue, Blue, Black, Gray, Tan,

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

ALS