



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Line-X LLC
301 James Record Rd., Suite 250
Huntsville, AL 35824, United States

Plant Location:

Lebanon, TN, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 11/11/2024

Material/Product:

Aromatic Polyurea Elastomer Coating.

Contact Temperature:

23 ± 2°C

Models:

XS-350



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum tank size (gallons): 10,000

Maximum tank surface area/volume ratio (sq in/L): 6.3

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7 days @ 23Â°C

Shortest cure time between coats or layers: 60min @ 23Â°C

Final cure time: 7 days

Mix ratio: 1:1 by Volume

Colors: Natural

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.