



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Sika Guatemala
15 calle 7-77 Zona 10, Edificio Optima Centro de Negocios
Nivel 5, Oficina 502
Ciudad de Guatemala 01010 , Guatemala

Plant Location:

Pal n Escuintla, Guatemala

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 09/29/2022

Material/Product:

Cementitious Waterproofing

Contact Temperature:

23 ± 2 C

Models:

Sika Monotop 107 Seal



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for “Lead Free” plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 400

Maximum tank surface area/volume ratio (sq in/L): 8.2

Maximum dry film thickness per coat (mils): 118 mil

Number of coats: If necessary: SCRATCH COAT (1-2 mm thickness, depending on the application)

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Yes

(1) Type of coat: Top Coat

(2) Number of additional coats: 1

Highest recommended percentage of thinner: 25%

Total cure time and temperature: 48 Hours @ 23°C

Shortest cure time between coats or layers: 24 Hours

Final cure time: 48 Hours

Mix ratio: 20-25%, 1:5 or 2:5 Water Thinner to Product

Colors: White/Gray

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.