



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

US Concrete Products
16 Greenmeadow Drive, Suite 111
Timonium, MD 21093, United States

Plant Location:

Baltimore, MD, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 01/11/2023

Material/Product:

Gunite 7001D

Contact Temperature:

23 ± 2°C

Models:

Gunite 7000W
Gunite 7001D
Gunite 7001W
Gunite 700D
Gunite 7041
Gunite 7424



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 7

Maximum pipe surface area/volume ratio (sq in/L): 34.9

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 4 hours at 5°C

Final cure time: 28 Days

Mix ratio: 8lb water :80lb bag

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

ALS