



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Quadex, LLC
18150 Imperial Valley Drive
Houston, TX 77060, United States

Plant Location:

Muskogee, OK, USA

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 05/25/2023

Material/Product:

GeoKrete-Water

Contact Temperature:

23 ± 2°C

Models:

GeoKrete-Water

NSF/ANSI/CAN 61 certified products meet the health effects criteria in NSF/ANSI/CAN 600.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 30

Maximum pipe surface area/volume ratio (sq in/L): 9.8

Minimum tank size (gallons): 1000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7 days @ 23C

Final cure time: 7 days

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

NSF/ANSI/CAN 61 certified products meet the health effects criteria in NSF/ANSI/CAN 600.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.