



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Pittsburg Tank and Tower Maintenance Company  
1412 Commonwealth Drive  
Henderson, KY 42420, United States

**Plant Location:**

Bedford, TX, USA

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 07/14/2025

**Material/Product:**

Elastomer Coatings

**Contact Temperature:**

23 ± 2°C

**Models:**

UniLine 19



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 10000

Maximum tank surface area/volume ratio (sq in/L): 6.3

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 7 days @ 23°C

Shortest cure time between coats or layers: 60min @ 23°C

Final cure time: 7 days

Mix ratio: 1:1 by Volume

Colors: Natural

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.