

ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

NCFI Polyurethanes 1515 Carter St Mt. Airy, NC 27030, United States

Plant Location:

Mt. Airy, NC, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 02/07/2024

Material/Product:

Polyurethane Foam.

Contact Temperature:

23 ± 2°C

Models:

24-039







10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Material Characteristics:

Minimum tank size (gallons): 1000 gallons

Maximum tank surface area/volume ratio (sq in/L): 5.7

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 30 minutes/ 43°C

Shortest cure time between coats or layers: 165 seconds

Final cure time: 30 minutes

Mix ratio: 1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

Product water contact should not exceed 5% of total wetted surface area.



