



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

PPG Industries, Inc.  
One PPG Place  
Pittsburg, PA 15272, United States

**Plant Location:**

Kansas City, Kansas, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022

**Certificate:**

Issued Date: 03/21/2024

**Material/Product:**

2k Polyurethane

**Contact Temperature:**

23 ± 2°C

**Models:**

Sigmafast 856



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 4 inches

Maximum pipe surface area/volume ratio (sq in/L): 61

Minimum tank size (gallons): 5 gallons

Maximum tank surface area/volume ratio (sq in/L): 40.4

Maximum dry film thickness per coat (mils): 250

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 14 days/ 72°F

Shortest cure time between coats or layers: 24 hours

Final cure time: 14 days

Mix ratio: 1:1

Colors: black, white, blue, green

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.