



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Titan Flow Control, Inc.
1401 Starlite Dr
Lumberton, North Carolina 28358, United States

Plant Location:

Chang Hua, Taiwan R.O.C.

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 03/25/2024

Material/Product:

Low Lead Check Valves and Y-Strainers

Contact Temperature:

23 ± 2°C

Models:

CV37NB
CV37TNB
YS57NB



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.