



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

US Concrete Products
16 Greenmeadow Drive, Suite 111
Timonium, MD 21093, United States

Plant Location:

Baltimore, MD, United States

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 04/01/2024

Material/Product:

US Thin Patch V/O

Contact Temperature:

23 ± 2°C

Models:

US Thin Patch V/O



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum pipe diameter (inches): 7 inches

Maximum pipe surface area/volume ratio (sq in/L): 34.9

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Shortest cure time between coats or layers: 1 hour at 5°C

Final cure time: 28 days

Mix ratio: 100 fl oz water per 50lb bag of material

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

ALS