



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Bedford, TX, United States

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 04/30/2025

Material/Product:

Polyeuro 7502 PW- Aliphatic Polyurea

Contact Temperature:

23 ± 2°C

Models:

Polyureo-7502 PW



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum tank size (gallons): 5000 gallon

Maximum tank surface area/volume ratio (sq in/L): 3.3

Maximum dry film thickness per coat (mils): 60-80

Number of coats: Several Passes

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24-48 hours

Shortest cure time between coats or layers: 0-6 hours

Final cure time: 24-48 hours

Mix ratio: 1:1

Colors: white/various

Is this paint/coating system intended to be applied to a pipe? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.