

ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

NCFI Polyurethanes 1515 Carter St Mt. Airy, NC 27030, United States

Plant Location:

Mt. Airy, NC, United States

Standards:

NSF/ANSI/CAN 61 - 2022 NSF/ANSI 372 - 2022

Certificate:

Issued Date: 09/09/2024

Material/Product:

2-component Polyurethane Foam

Contact Temperature:

23 ± 2°C

Models:

24-035







10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Material Characteristics:

Minimum pipe diameter (inches): 15

Maximum pipe surface area/volume ratio (sq in/L): 16.3

Minimum tank size (gallons): 3000

Maximum tank surface area/volume ratio (sq in/L): 4

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N):

Total cure time and temperature: 24hr/ 23ºC

Mix ratio: 1:1 by volume

Colors: Cream/yellow, orange, pink, grey, ANY

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



