



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Polycoat Products  
14722 Spring Avenue  
Santa Fe Springs, CA 90670-5108, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 09/19/2024

**Material/Product:**

Polyprime 3042 & Polyeuro 1050H- Polyurethane Barrier Materials

**Contact Temperature:**

23 ± 2°C

**Models:**

Polyprime 3042 w/ Polyeuro 1050H



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 8

Maximum pipe surface area/volume ratio (sq in/L): 30.5

Minimum tank size (gallons): 1000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N):

Total cure time and temperature: 5 day at 23°C

Final cure time: 5 day

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): No

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

ALS