



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

PPG Coatings Europe B.V.
Oceanenweg 2
Amsterdam 1047 BB, Netherlands

Plant Location:

Tepexpan, Acolman , Estado de Mexico , Mexico

Standards:

NSF/ANSI/CAN 61 - 2022
NSF/ANSI 372 - 2022

Certificate:

Issued Date: 03/05/2025

Material/Product:

Two-component, solvent-free polyurethane coating

Contact Temperature:

23 ± 2°C

Models:

Sigmaline 855 (11)



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 20

Maximum pipe surface area/volume ratio (sq in/L): 12.2

Maximum dry film thickness per coat (mils): 60 mils

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 72 hours/ 23°C

Final cure time: 72 hours

Mix ratio: 1:1

Colors: blue, off-white

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.