



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Max Air Technology, Inc.
114 Resource Drive,
Wentzville, MO 63385, United States

Plant Location:

Seoul, South Korea

Standards:

NSF/ANSI/CAN 61 - 2024
NSF/ANSI 372 - 2024

Certificate:

Issued Date: 04/11/2025

Material/Product:

Butterfly Valve

Contact Temperature:

82 ± 2°C

Models:

800 Series [1,2,3,4]

- [1] Commercial Hot
- [2] Carbon Steel or Stainless Steel Body
- [3] Stainless Steel Disc
- [4] TFM or PTFE Seats



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.