



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Polycoat Products
14722 Spring Avenue
Santa Fe Springs, CA 90670-5108, United States

Plant Location:

Santa Fe Springs, CA, United States

Standards:

NSF/ANSI/CAN 61 - 2024
NSF/ANSI 372 - 2024

Certificate:

Issued Date: 06/27/2025

Material/Product:

Polyeuro 802 - Spray Applied Polyurethane Coating

Contact Temperature:

23 ± 2°C

Models:

Polyeuro 802



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 18

Minimum tank size (gallons): 6000

Maximum dry film thickness per coat (mils): 121

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 24hrs at $23 \pm 2^{\circ}\text{C}$

Final cure time: 24hrs at $23 \pm 2^{\circ}\text{C}$

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

ALS