



# ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Warren Environmental and Coatings, LLC.  
1596 Fulenwider Road  
Gainesville, GA 30507, United States

**Plant Location:**

Gainesville, GA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI 372 - 2022

**Certificate:**

Issued Date: 06/06/2025

**Material/Product:**

301-01-5

**Contact Temperature:**

23 ± 2°C

**Models:**

301-01-5



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum pipe diameter (inches): 6

Minimum tank size (gallons): 1000

Maximum dry film thickness per coat (mils): 125-500

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 days at  $23 \pm 2^{\circ}\text{C}$

Final cure time: 5 days at  $23 \pm 2^{\circ}\text{C}$

Mix ratio: 2:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Certified for new and installed pipe.

A one hour flush is required prior to being placed into service.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.