



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

HMI
4466 Custer St
Manitowoc, Wisconsin 54220, United States

Plant Location:

Manitowoc, Wisconsin, United States

Standards:

NSF/ANSI/CAN 61 - 2024
NSF/ANSI 372 - 2024

Certificate:

Issued Date: 07/18/2025

Material/Product:

FillFoam/Void Filling Foam

Contact Temperature:

23 ± 2°C

Models:

FillFoam/Void Filling Foam

Product is designed for void filling or other geotechnical applications outdoors and may come into contact with less than 1% of groundwater/runoff



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum pipe diameter (inches): 23

Maximum pipe surface area/volume ratio (sq in/L): 68.4

Minimum tank size (gallons): 700

Maximum tank surface area/volume ratio (sq in/L): 42.6

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 24 hours at $23 \pm 2^{\circ}\text{C}$

Final cure time: 24 hours at $23 \pm 2^{\circ}\text{C}$

Mix ratio: 1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes