



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Warren Environmental and Coatings, LLC.
1596 Fulenwider Road
Gainesville, GA 30507, United States

Plant Location:

Gainesville, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2024
NSF/ANSI 372 - 2024

Certificate:

Issued Date: 06/06/2025

Material/Product:

301-CF

Contact Temperature:

23 ± 2°C

Models:

301-CF



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



Material Characteristics:

Minimum pipe diameter (inches): 16

Minimum tank size (gallons): 1000

Maximum dry film thickness per coat (mils): 80-300

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 days at $23 \pm 2^{\circ}\text{C}$

Final cure time: 5 days at $23 \pm 2^{\circ}\text{C}$

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Certified for new and installed pipe.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.