



ALS Group USA, Corp.

10450 Stancliff Rd. Suite 210 Houston, Texas 77099

Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

Warren Environmental and Coatings, LLC.
1596 Fulenwider Road
Gainesville, GA 30507, United States

Plant Location:

Gainesville, GA, United States

Standards:

NSF/ANSI/CAN 61 - 2023
NSF/ANSI 372 - 2023

Certificate:

Issued Date: 06/06/2025

Material/Product:

301-01-2

Contact Temperature:

23 ± 2°C

Models:

301-01-2



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 6

Minimum tank size (gallons): 1000

Maximum dry film thickness per coat (mils): 120-300

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 5 days @ 23 ± 2°C

Final cure time: 5 days @ 23 ± 2°C

Mix ratio: 2:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Certified for new and installed pipe.

A one hour flush is required prior to being placed into service.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.